

# 2023 Consumer Confidence Report for Public Water System HARRIS COUNTY MUD 191

This is your water quality report for  
January 1 to December 31, 2023

Harris County Municipal Utility District No. 191 ("HARRIS COUNTY MUD 191") provides: (1) Surface Water sourced from **Lake Houston (on the San Jacinto River), treated at the Northeast Water Purification Plant (City of Houston)** and purchased from the North Harris County Regional Water Authority, **all located in Harris County, Texas**, and (2) Groundwater sourced from **a well (Gulf Coast Aquifer)** located in **Harris County, Texas**

For more information regarding this report  
contact:

Name: Jacob Williams, H<sub>2</sub>O Innovation  
(operating company, system business  
office)

Phone: (281) 353-9809

Este reporte incluye información importante  
sobre el agua para tomar. Para asistencia en  
español, favor de llamar al telefono:  
(281) 353-9809

## Definitions and Abbreviations

**Definitions and Abbreviations**      **The following tables contain scientific terms and measures, some of which may require explanation.**

Action Level: (AL):	The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.
Average (Avg.):	Regulatory compliance with some MCLs are based on running annual average of monthly samples.
Maximum Contaminant Level or MCL:	The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
Maximum Contaminant Level Goal or MCLG:	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
Maximum residual disinfectant level or MRDL:	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum residual disinfectant level goal or MRDLG:	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
na:	not applicable.
NTU:	nephelometric turbidity units (a measure of turbidity)
pCi/L:	picocuries per liter (a measure of radioactivity)
ppb:	parts per billion or micrograms per liter (µg/L); or one ounce in 7,350,000 gallons of water.
ppm:	parts per million, or milligrams per liter (mg/L); or one ounce in 7,350 gallons of water.
Treatment Technique (TT):	A required process intended to reduce the level of a contaminant in drinking water.

## Information about your Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office.

**You may be more vulnerable than the general population to certain microbial contaminants; such as *Cryptosporidium*, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; persons who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care provider. Additional guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* are available from the Safe Drinking Water Hotline (800-426-4791).**

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. HARRIS COUNTY MUD 191 is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

## Opportunities for public participation

Opportunities for public participation in decisions that may affect the quality of the water include attendance at meetings of the Board of Directors of HARRIS COUNTY MUD 191, usually held on the fourth Wednesday of the month at 6:30 PM, but sometimes meetings are rescheduled (or special meetings are called). The current meeting place is the Champions MPC Clubhouse, 13719 Champions Centre Drive, Houston, Texas 77069, but the place may be changed. For specific information on Board meetings, consult notice(s) posted on the bulletin board at the Champions MPC Clubhouse, 13719 Champions Centre Drive, Houston, Texas 77069 or on the internet at <https://hcmud191.org/meetings/>. You may contact Jacob Williams, H2O innovation (operating company, system business office), at (281) 353-9809 for information about water quality and Board meetings and to provide input into decisions that may affect the quality of the water.

**Information about Source Water** HARRIS COUNTY MUD 191 purchases surface water from NORTH HARRIS COUNTY REGIONAL WATER AUTHORITY sourced from **Lake Houston (on the San Jacinto River)** and treated at the **Northeast Water Purification Plant (City of Houston)**, all located in **Harris County, Texas**. HARRIS COUNTY MUD 191 also produces **groundwater from a well (Gulf Coast Aquifer)** located in **Harris County, Texas**. Water from both sources is combined in the storage and distribution systems of HARRIS COUNTY MUD 191.

TCEQ completed an assessment of HARRIS COUNTY MUD 191's source water, and results indicate that some of such sources are susceptible to certain contaminants. The sampling requirements for the HARRIS COUNTY MUD 191 water system are based on this susceptibility and previous sample data. Any detections of these contaminants will be found in this Consumer Confidence Report, and the data presented in this report is from the most recent testing done in accordance with the regulations (but not older than five years). For more information on source water assessments and protection efforts at our system contact Jacob Williams, H2O innovation (operating company, system business office) at (281) 353-9809.

## 2023 Water Quality Test Results

*Information about Surface Water  
Sourced from Lake Houston (on the San Jacinto River) and  
Treated at the Northeast Water Purification Plant (City of Houston)  
(data from TCEQ, Drinking Water Watch, <https://dww2.tceq.texas.gov/DWW/> for  
Water System No. TX1010013, Sampling Point EP141, except as noted)*

Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation (Y/N)	Likely Source of Contamination
Barium	2023	0.042	0.042 – 0.042	2	2	ppm	N	Discharge of drilling wastes.
Nitrate [measured as Nitrogen]	2023	0.45	0.45 – 0.45	10	10	ppm	N	Runoff from fertilizer use.
Fluoride	2022	0.1	0.1 – 0.1	4	4	ppm	N	Erosion of natural deposits.
Cyanide	2022	0.04	0.04 – 0.04	200	200	ppb	N	Discharge from plastic/metal refineries.

Synthetic organic contaminants including pesticides and herbicides	Collection Date	Average Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation (Y/N)	Likely Source of Contamination
Atrazine	2023	0.29	0.29 – 0.29	3	3	ppb	N	Runoff from herbicides used on row crops.
Simazine	2023	0.15	0.15 – 0.15	4	4	ppb	N	Herbicide runoff.

Unregulated Contaminants**	Collection Date	Highest Level Detected	Range of Individual Samples	Units
Chloroform	2023	18.0	18.0 – 18.0	ppb
Bromodichloromethane	2023	3.0	3.0 – 3.0	ppb

\*\* Unregulated contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulation is warranted. The unregulated contaminants displayed in this table are those: (i) which were detected, and (ii) for which monitoring is required by 40 CFR §141.40, and found in 30 TAC §290.275(4) (except *Cryptosporidium*).

*(Turbidity data from North Harris County Regional Water Authority)*

Turbidity*	Level Detected	Limit (Treatment Technique)	Violation (Y/N)	Likely Source of Contamination
Highest single measurement	0.27 NTU	1 NTU	N	Soil runoff.
Lowest monthly % meeting limit	100%	0.3 NTU (rounded)	N	Soil runoff.

\*Information Statements: (1) Turbidity is a measurement of the cloudiness of the water caused by suspended particles. It is monitored because it is a good indicator of water quality and the effectiveness of the filtration system and disinfectants. (2) Turbidity has no health effects. However, turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.

*Additional information about Surface Water  
Sourced from Lake Houston (on the San Jacinto River),  
Treated at the Northeast Water Purification Plant (City of Houston) and  
Purchased from NORTH HARRIS COUNTY REGIONAL WATER AUTHORITY  
(additional data provided by NHCRWA from TCEQ-generated CCR for NHCRWA)*

Inorganic Contaminants	Collection Date	Average Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation (Y/N)	Likely Source of Contamination
Nitrate [measured as Nitrogen]	2023	0.21	0.21 – 0.21	10	10	ppm	N	Runoff from fertilizer use.

Disinfection By-Products	Collection Date	Highest Level Detected*	Range of Individual Samples	MCLG	MCL	Units	Violation (Y/N)	Likely Source of Contamination
Haloacetic Acids (HAA5)	2023	17.7	17.7 – 17.7	No goal for the total	60	ppb	N	By-product of drinking water disinfection.
Total Trihalo-methanes (TTHM)	2023	15.5	15.5 – 15.5	No goal for the total	80	ppb	N	By-product of drinking water disinfection.

\* The value in the Highest Level or Average Detected column is the highest average of all HAA5 or TTHM sample results collected at a location over a year.

*Information about Combination of Surface Water (purchased from NHCRWA) and  
Groundwater (produced by HARRIS COUNTY MUD 191)*

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation (Y/N)	Likely Source of Contamination
Copper	2021	1.3	1.3	0.0936	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.
Lead	2021	0	15	2.36	0	ppb	N	Corrosion of household plumbing systems; Erosion of natural deposits.

Disinfection By-Products	Collection Date	Highest Level Detected*	Range of Individual Samples	MCLG	MCL	Units	Violation (Y/N)	Likely Source of Contamination
Haloacetic Acids (HAA5)	2023	17 (rounded)	17.1 – 17.1	No goal for the total	60	ppb	N	By-product of drinking water disinfection.
Total Trihalo-methanes (TTHM)	2023	16 (rounded)	16.1 – 16.1	No goal for the total	80	ppb	N	By-product of drinking water disinfection.

\* The value in the Highest Level or Average Detected column is the highest average of all HAA5 or TTHM sample results collected at a location over a year.

Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation (Y/N)	Likely Source of Contamination
Barium	2022	0.112	0.112 - 0.112	2	2	ppm	N	Discharge of Drilling wastes.
Fluoride	2023	0.14	0.14 – 0.14	4	4.0	ppm	N	Erosion of natural deposits.
Nitrate [measured as Nitrogen]	2023	0.11	0.11 – 0.11	10	10	ppm	N	Runoff from fertilizer use.

Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation (Y/N)	Likely Source of Contamination
Uranium	08/08/2018	1.6	1.6 - 1.6	0	30	µg/L	N	Erosion of natural deposits.

Synthetic organic contaminants including pesticides and herbicides	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation (Y/N)	Likely Source of Contamination
Atrazine	08/19/2021	0.16	0.16 - 0.16	3	3	ppb	N	Runoff from herbicide used on row crops.

Disinfectant Residual

Disinfectant Residual	Year	Average Level	Range of Levels Detected	MRDL	MRDLG	Unit of Measure	Violation (Y/N)	Source in Drinking Water
Total Chlorine	2023	3.39*	1.68 – 4.00	4*	4*	ppm	N	Water additive used to control microbes.

\*Indicates levels computed or set as running annual averages. ("Range of Levels Detected" includes individual levels, not averages.)

Unregulated Contaminants**	Collection Date	Average	Range of Individual Samples	Units
Chloroform	2023	14.6	13.2 – 16.0	ppb
Bromochloroacetic Acid	2023	2.6	2.6 – 2.6	ppb
Dichloroacetic Acid	2023	13.8	13.8 – 13.8	ppb
Bromodichloromethane	2023	3.15	2.9 – 3.4	ppb
Trichloroacetic Acid	2023	3.3	3.3 – 3.3	ppb
Monochloroacetic Acid	2021	2.5	2.5 – 2.5	ppb

\*\*Unregulated contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulation is warranted. The unregulated contaminants displayed in this table are those: (i) which were detected, and (ii) for which monitoring is required by 40 CFR §141.40, and found in 30 TAC §290.275(4) (except *Cryptosporidium*).