

GENERAL CONSTRUCTION NOTES

- 1. WASTEWATER COLLECTION SYSTEMS, WATER, PAVING, TRAFFIC SIGNALS AND DRAINAGE SYSTEMS SHALL BE CONSTRUCTED IN ACCORDANCE WITH THE FOLLOWING CITY DOCUMENTS...

WATERLINE CONSTRUCTION NOTES

- 1. ALL FOUR (4) INCH THROUGH TWELVE (12) WATERLINES TO BE CLASS 150 (DR-18), PVC (AWWA C-900), OR DUCTILE IRON AS SPECIFIED...

SANITARY SEWER CONSTRUCTION NOTES

- 1. ALL PROPOSED 8-INCH TO 12-INCH GRAVITY SANITARY SEWER LINES WILL BE DUCTILE IRON OR SDR 26 PVC PIPE ASTM D-3034, UNLESS OTHERWISE NOTED ON PLANS...

PROTECTION REQUIREMENTS AT WATER LINE - SANITARY SEWER CROSSINGS

Table with columns: PRIMARY CONDITION, PROPOSED WATER - EXISTING SANITARY, PROPOSED WATER - PROPOSED SANITARY OR EXISTING WATER - PROPOSED SANITARY, SECONDARY CONDITIONS, IF THE CLEARANCE IS, PROTECTION REQUIREMENT.

PROTECTION REQUIREMENTS FOR SANITARY SEWER CROSSINGS (UNLESS VARIANCE IS GRANTED BY THE TCEQ) (ALL CLEARANCES SHALL BE MEASURED FROM OUTSIDE WALL TO OUTSIDE WALL)

- 1. PLACE ONE FULL SECTION OF APPROVED JOINT WATER LINE CENTERED AT SANITARY SEWER. NOT APPLICABLE FOR EXISTING WATER.

SPECIAL NOTES: LOCATION OF SANITARY SEWER FACILITIES

- 1. THE CONTRACTOR IS RESPONSIBLE FOR PROVIDING RED LINE RECORD DRAWINGS (INCLUDING MEASUREMENTS FROM TWO FIXED OBJECTS TO ENDS OF SANITARY SEWER SERVICES) AT THE COMPLETION OF THIS JOB.

UTILITY NOTES

- 1. "CENTER POINT" ENERGY (ELECTRICAL FACILITIES) OVERHEAD LINES MAY EXIST ON THE PROPERTY. WE HAVE NOT ATTEMPTED TO MARK THOSE LINES SINCE THEY ARE CLEARLY VISIBLE...

CAUTION: UNDERGROUND GAS FACILITIES

LOCATIONS OF CENTERPOINT ENERGY GAS FACILITY MAIN LINES (TO INCLUDE UNIT GAS TRANSMISSION AND/OR GAS SUPPLY CORPORATION WHERE APPLICABLE) ARE SHOWN IN AN APPROXIMATE LOCATION ONLY...

-WHEN CENTERPOINT ENERGY GAS FACILITY PIPE LINE MARKINGS ARE NOT VISIBLE, CALL (713) 967-8037 (7:00 AM TO 4:30 PM) FOR STATUS OF LINE LOCATION REQUEST BEFORE EXCAVATION BEGINS.

-WHEN EXCAVATING WITHIN EIGHTEEN INCHES (18") OF THE INDICATED LOCATION OF CENTERPOINT ENERGY FACILITIES, ALL EXCAVATION MUST BE ACCOMPLISHED USING NON-MECHANIZED EXCAVATION PROCEDURES.

-WHEN CENTERPOINT ENERGY FACILITIES ARE EXPOSED, SUFFICIENT SUPPORT MUST BE PROVIDED TO THE FACILITIES TO PREVENT EXCESSIVE STRESS ON THE PIPING.

THE CONTRACTOR IS FULLY RESPONSIBLE FOR ANY DAMAGES CAUSED BY THE CONTRACTOR'S FAILURE TO EXACTLY LOCATE AND PRESERVE THESE UNDERGROUND FACILITIES.

CAUTION: UNDERGROUND ELECTRICAL FACILITIES

UNDERGROUND ELECTRICAL FACILITIES EXIST IN THE AREA OF THIS PROJECT. DO NOT BEGIN CONSTRUCTION UNTIL THESE FACILITIES HAVE BEEN LOCATED AND STAKED. TO HAVE THESE UNDERGROUND FACILITIES STAKED, CALL THE UTILITY COORDINATING COMMITTEE AT (713) 223-4567, OR TOLL FREE AT 1-800-669-8344, AT LEAST 48 HOURS PRIOR TO ANY CONSTRUCTION.

SBC FACILITIES

THE LOCATIONS OF SBC FACILITIES ARE SHOWN IN AN APPROXIMATE WAY ONLY. THE CONTRACTOR SHALL DETERMINE THE EXACT LOCATION BEFORE COMMENCING WORK. HE AGREES TO BE FULLY RESPONSIBLE FOR ANY AND ALL DAMAGES WHICH MIGHT BE OCCASIONED BY THIS FAILURE TO EXACTLY LOCATE AND PRESERVE THESE UNDERGROUND UTILITIES.

THE CONTRACTOR SHALL CALL 1-800-344-8377 A MINIMUM OF 48 HOURS PRIOR TO CONSTRUCTION TO HAVE UNDERGROUND LINES FIELD LOCATED.

WHEN EXCAVATING WITHIN EIGHTEEN INCHES (18") OF THE INDICATED LOCATION OF SBC FACILITIES, ALL EXCAVATIONS MUST BE ACCOMPLISHED USING NON-MECHANIZED EXCAVATION PROCEDURES. WHEN BORING, THE CONTRACTOR SHALL EXPOSE THE SBC FACILITIES.

WHEN SBC FACILITIES ARE EXPOSED, THE CONTRACTOR WILL PROVIDE SUPPORT TO PREVENT DAMAGE TO THE CONDUIT DUCTS OR CABLES. WHEN EXCAVATING NEAR TELEPHONE POLES, THE CONTRACTOR SHALL BRACE THE POLE FOR SUPPORT.

TIME WARNER CABLE FACILITIES

THE LOCATIONS OF TIME WARNER CABLE FACILITIES ARE SHOWN IN AN APPROXIMATE WAY ONLY. THE CONTRACTOR SHALL DETERMINE THE EXACT LOCATION BEFORE COMMENCING WORK. CONTRACTOR AGREES TO BE FULLY RESPONSIBLE FOR ANY AND ALL DAMAGES, WHICH MIGHT BE OCCASIONED BY THIS FAILURE TO EXACTLY LOCATE AND PRESERVE THESE UNDERGROUND UTILITIES.

THE CONTRACTOR SHALL CALL TEXAS ONE AT 1-800-245-4545 A MINIMUM OF 48 HOURS PRIOR TO CONSTRUCTION TO HAVE UNDERGROUND LINES FIELD LOCATED.

WHEN EXCAVATING WITHIN EIGHTEEN INCHES (18") OF THE INDICATED LOCATION OF TIME WARNER CABLE FACILITIES, ALL EXCAVATIONS MUST BE ACCOMPANIED USING NON-MECHANIZED EXCAVATION PROCEDURES. WHEN BORING, THE CONTRACTOR SHALL EXPOSE THE TIME WARNER CABLE FACILITIES.

WHEN TIME WARNER CABLE FACILITIES ARE EXPOSED, THE CONTRACTOR WILL PROVIDE SUPPORT TO PREVENT DAMAGE TO THE CONDUIT DUCTS OR CABLES. WHEN EXCAVATING NEAR TELEPHONE POLES, THE CONTRACTOR SHALL BRACE THE POLE FOR SUPPORT.

THE CONTRACTOR IS FULLY RESPONSIBLE FOR ANY DAMAGES CAUSED BY THE CONTRACTOR'S FAILURE TO EXACTLY LOCATE AND PRESERVE THESE UNDERGROUND FACILITIES.

CONTRACTOR WORK ZONE NOTES

- 1. DRIVEWAY ACCESS WILL BE MAINTAINED OPEN AFTER WORKING HOURS. A MINIMUM OF ONE DRIVEWAY ACCESS WILL BE MAINTAINED OPEN AT ALL TIMES TO COMMERCIAL, APARTMENTS, AND/OR NON-RESIDENTIAL DEVELOPMENTS...

WATER LINE CONSTRUCTION NOTES

- 1. CONTRACTOR SHALL CONTACT THE DISTRICT OPERATOR PRIOR TO MAKING ANY CONNECTION TO THE EXISTING WATER LINES OR ANYTIME A VALVE ON AN EXISTING WATER LINE IS TO BE OPENED OR CLOSED.



PRIVATE UTILITY LINES SHOWN AT LEAST 48 HOURS BEFORE EXCAVATING IN STREET R.O.W. OR EASEMENTS CALL THE LONE STAR NOTIFICATION 713-223-4567. Includes signature lines, dates, and project information for Harris County M.U.D. No. 191.

RECORD DRAWING

